

Part L2 Compliance Report Clitheroe Care Home PA1674



RIBA	0	1	2	2	4	F	C	7
STAGE:	0	1	Z	3	4	Э	D	/

TACE | Portland House | Oak Green | Earl Road | Cheadle Hulme | Cheshire | SK8 6QL

Controlled Document

TACE Project Ref:		PA1674		
	Name		Signature	Date
Prepared by:	Ali Syed		Æ	16.03.23
Checked:	Stephan Senior		Sseron	16.03.23
TACE Approved:	James Massey		A	16.03.23

Revisio	Revision Record						
Rev.	Date	Ву	Summary of Changes	Chkd	Aprd		
А	03.02.23	AS	Preliminary Issue	SS	JM		
В	16.03.23	JL	Updated U-values inline with architects email	SS	JM		

Contents

1.0	Execu	utive Summary	1
1.1	Pla	anning	1
1.2	Lo	w or Zero Carbon (LZC)	1
1.3	Bu	uilding Regulations Part L2A 2013	1
2.0	Intro	duction	5
2.1	So	oftware	5
2.2	Lo	cation	5
3.0	Ener	gy & Sustainability Strategy	5
3.1	Int	troduction6	5
3	.1.1	Lean – Building Passive Measures	7
3	.1.2	Mean – High-Efficiency Systems, Plant and Controls	3
3.	.1.3	Green – Renewable Technologies)
4.0	Mech	hanical Services Design Criteria)
5.0	Elect	rical Services Design Criteria12	L
6.0	Conc	lusion13	3
Appen	dix I –	- BRUKL Report	1
Appen	dix II -	– EPC	5

1.0 Executive Summary

This report has been prepared to satisfy the requirements of Eric Wright Developer and Borough of Ribble Valley targets to demonstrate that, that thorough consideration has been given to the energy use and carbon consumption of the proposed new care home at Clitheroe.

The proposed development complies with the requirements of the Building Regulations Approved Document L2 (ADL2) 2021.

1.1 Planning

The Local Planning Authority (LPA) is borough of Ribble Valley, Lancashire.

1.2 Low or Zero Carbon (LZC)

With Passive measures incorporated within the design of the proposed development it was not possible to achieve required BER over TER, therefore, passive measures alone are not enough and so renewables were adopted within the design philosophy. At this stage the advised source of renewable energy is photovoltics.

1.3 Building Regulations Part L2A 2013

This building is currently complying with Part L2A 2021 with an actual building emissions rate (BER) demonstrating 5.2% reduction in carbon emissions in comparison with the notional building target emissions rate (TER).

The CO ₂ emission and prim	ary energy rates of the building	must not exceed	I the targets
Target CO ₂ emission rate (TER),	kgCO ₂ /m ² annum	12.37	
Building CO ₂ emission rate (BER), kgCO₂/m²annum	11.73	
Target primary energy rate (TPE	R), kWh/m²annum	134.24	
Building primary energy rate (BPI	ER), kWh/m²annum	126.26	
Do the building's emission and pr	imary energy rates exceed the targets?	BER =< TER	BPER =< TPER
	Energy Performance Certificate HMGovernment Non-Domestic Building Citheres Certificate Reference No Certificate Referenc	nt mber: 3-3152	
	Respectively of the part of th	of de la biologica de la construcción de la constru	

From the attached sketch of Criterion 1 and EPC, it can be seen the building not just comply with the Building Regulation Part L2A, but also achieve EPC rating A.

TACE

2.0 Introduction

TACE have been appointed to develop model and perform Part L2A analysis for new care home development Clitheroe Care Home, Standen Central Site, Clitheroe.

This developed comprises of 2 storey care home containing around 70 ensuite bedrooms for the elderly. While on the ground floor beside ensuite bedrooms, the floor also contains admin and manager offices, dining rooms, lounges, hair saloon, library, seating area and bar. While the first floor contains ensuite bedrooms, dining areas, cinema, activities.

This report is about the areas within the building which falls under Building Regulations Part L2A.



Proposed development

2.1 Software

This study has been undertaken using TAS dynamic simulation software V9.5.4 and UK Building regulations 2021 studio to generate a BRUKL and EPC rating. This allows us to assess the building servicing strategy and energy profiles.



2.2 Location

The weather file selected for the project is Manchester in accordance with the SBEM weather locations application.

The proposed development is situated at Standen Central Site, Clitheroe.



Project location

3.0 Energy & Sustainability Strategy

3.1 Introduction

A sustainable building will be delivered through the utilisation of a holistic approach, which considers, plans and monitors the use of natural resources. The strategy for achieving this is outlined as follows:

The Low Carbon Design Hierarchy

The strategy for reducing carbon dioxide (CO_2) emissions and energy consumption within the temporary accommodation, development will be to embrace a lean, mean and green approach as defined below.

- Lean the use of advanced building modelling software and passive construction techniques.
- Mean Incorporation of high-efficiency systems and effective controls throughout the design.
- Green Incorporation of renewable energy sources where possible



3.1.1 Lean – Building Passive Measures

The passive measures are to be included within the design of the development to reduce energy use and the associated CO_2 emissions are;

- Improved building fabric parameters over those required by Building Regulations Part L2A 2021
- Windows with high thermal insulation
- Improved air permeability
- Maximisation of daylight
- Optimise glazing solar energy transmittance

Enhanced Insulation to The Building Envelope

Limiting heat losses across the entire building envelope will future proof the energy efficiency of the development over its whole life. To achieve this, the fabric thermal U-Value requirements as detailed within Approved Document L2A 2021 of the Building Regulations will be improved upon.

The table below shows the limiting U-values required to meet Building Regulations compared to the targeted values which exceed the Building Regulations requirements.

The targeted values as noted will be confirmed during the detailed design stage of the building in conjunction with finalisation of the energy efficiency measures included to meet the CO₂ emission rates required by Building Regulations.

Building Element	Building Regulations Limiting Value (W/m ² . K)	Proposed Construction Value (W/m ² . K)
Roof Pitched	0.16	0.16
External Wall	0.26	0.22
Floor	0.25	0.12
Windows & Door	1.6	1.2



Engineered Facade Design

The glazed proportion of the building facades and the glazing location will be designed to maximise the use of natural daylight to offset demand for artificial lighting.

Building Element	AD L2A Solar G Value	Target Solar G Value
Glazed Units	0.7	0.4

Reduced Air Permeability

The development will be constructed to improved building airtightness criteria beyond the level required to comply with Building Regulations.

Building Regulations Document	Maximum allowable air permeability (m³/m².hr at 50 Pa)	Targeted air permeability (m³/m².hr at 50 Pa)
Approved Document L2A	8.0	5.0

Weather File

For the analysis, the weather file used was Manchester.TRY weather file taken from CIBSE weather data.

3.1.2 Mean – High-Efficiency Systems, Plant and Controls

High-efficiency systems, plant, controls and equipment will be incorporated as follows:

Optimised Plant Controls

Control of heating and cooling plant will be optimised, and weather compensated to ensure plant operates as close to demand as possible and not at full capacity.

Variable Speed Drives

Variable speed drives shall be installed on circulation pumps and ventilation fans to allow the speed of the respective motors to be amended by the automatic controls to suit changing load of the building. This will ensure energy usage matches demand requirements.

Energy Efficient LED Lighting

Internal lighting within the landlord areas will incorporate energy-efficient LED lighting where practicable.

Lighting controls will be provided to limit energy use.

Automatic presence/absence detection will be included in appropriate areas. This form of control will ensure lights are automatically switched off during periods of non-occupancy.

External lighting will be designed to incorporate energy efficient luminaires and an automatic lighting control system utilising daylight sensors and time clock control to ensure energy-efficient operation of the lighting.

Heat Recovery on Ventilation Systems

Where installed, the ventilation systems installed within the development will also incorporate heat recovery units within the building. This is then used to heat the incoming fresh air and therefore reduce energy usage.

The heat recovery units will have a low specific fan power to minimise the energy used by the fans.

3.1.3 Green – Renewable Technologies

The design of the building as detailed above place emphasis on passive energy saving by careful design of the building and the building services.

The thermal modelling undertaken based on the TACE M&E design strategy demonstrates that the passive design measures in conjunction with solar photovoltics will meet the CO₂ requirement for Building Regulation Part L2A 2021 compliance.

PV data used for the Part L2A analysis is as followed.

- Total PV Area = 70m²
- PV Efficiency = 20%
- PV Inclination = 30°
- PV Orientation = South Facing
- Total PV Area = 110m²
- PV Efficiency = 20%
- PV Inclination = 30°
- PV Orientation = East Facing
- Total PV Area = 50m²
- PV Efficiency = 20%
- PV Inclination = 30°
- PV Orientation = West Facing

With the inclusion of 230m² of PV area for the care home recommended by EDSL TAS thermal modelling analysis the building achieve improvement over TER.

4.0 Mechanical Services Design Criteria

The modelled mechanical services systems, configurations and efficiencies are all based on the current TACE design. Any deviations need to be carefully considered to ensure the minimum efficiencies are achieved.



It is the responsibility of the contractor as part of his plant selection and installation to implement these measures. Should the contractor deviate from these assumptions he will be responsible for producing a revised Part L calculation and report to demonstrate compliance.

The following table summarises the strategy adopted by TACE to the mechanical services installation:

Type of system	Sys	tem Performance Data	System Performance
Heating System	2) Hoa	t Source Constator Type	Flectric Papel Heaters
All Zones	a) fied b) Fue		Grid Supplied Electricity
All Zones	c) Cor	arator Seasonal Efficiency	
zones fitted	d) Hea	t Pacovery Effectiveness	N/A
with V/DE/V/DV/ &	a) Dali	ivery Efficiency	100%
Underfloor	ej Den		100%
Heating			
Heating System	2) Hoa	t Source Generator Type	ленр
Zones with	a) fied b) Euo		Grid Supplied Electricity
Linder Floor	D) Fue	arator Soconal Efficiency	
Under Flour	d) Her	the Recovery Effectiveness	5.45 N/A
пеацінд	u) Hea	in Recovery Effectiveness	
	e) Den		N/A
Heating System	a) Hea	t Source Generator Type	ASHP
Comms Room	b) Fue	I Туре	Grid Supplied Electricity
	c) Ger	erator Seasonal Efficiency	410%
	d) Hea	t Recovery Effectiveness	N/A
	e) Deli	ivery Efficiency	100%
Heating System	a) Hea	t Source Generator Type	ASHP
Zones with VRF	b) Fue	l Type	Grid Supplied Electricity
	c) Ger	nerator Seasonal Efficiency	300%
	d) Hea	t Recovery Effectiveness	N/A
	e) Deli	ivery Efficiency	100%
	·		
Cooling System	a) Hea	It Source Generator Type	ASHP
VRF/VRV	b) Fue	l Type	Grid Supplied Electricity
	c) Ger	nerator Seasonal Efficiency	4.0
	d) Hea	t Recovery Effectiveness	N/A
	f) Deli	ivery Efficiency	100%
	·		
Cooling System	a) Hea	t Source Generator Type	ASHP
HP	b) Fue	I Туре	Grid Supplied Electricity
	c) Ger	erator Seasonal Efficiency	7%
	d) Hea	t Recovery Effectiveness	N/A
	e) Deli	ivery Efficiency	100%

DHW	a)	Method of DHW generation, i.e.	Air Source Heat Pump
		combi boilers, cylinder, etc.	
	b)	Size and type of DHW cylinder	2000L
	c)	DHW delivery efficiency	95%
	d)	Fuel Type	Grid Supplied Electricity
	e)	Generator Seasonal Efficiency	N/A
Mechanical	a)	Details of all AHUs and which areas	HRU
Ventilation		served by AHU	
HRU	b)	Specific fan power of AHUs (W/I/s)	1.8W/I/s
	c)	Efficiency of heat recovery	80%
Mechanical	a)	Details of all AHUs and which areas	Kitchen S&E
Ventilation		served by AHU	
Kitchen S&E	b)	Specific fan power of AHUs (W/I/s)	0.6 + 0.6 W/I/s
	c)	Efficiency of heat recovery	N/A
Mechanical	d)	Details of all AHUs and which areas	Extract Only
Ventilation		served by AHU	
Extract Only	e)	Specific fan power of AHUs (W/I/s)	0.5 W/I/s
Laundry,	f)	Efficiency of heat recovery	N/A
Cleaners,			
Bathrooms			
Control	a)	Are there system provisions for	Yes
Corrections		metering?	
	b)	Does the system warn of 'out of	No
		range' values?	Following controls are
			installed on HVAC
			systems
			a) Room
			Temperature
			Control
			b)

5.0 Electrical Services Design Criteria

The modelled services systems, configurations and efficiencies are all based on the current TACE design. Any deviations need to be carefully considered to ensure the minimum efficiencies are achieved.

It is the responsibility of the contractor as part of his plant selection and installation to implement these measures. Should the contractor deviate from these assumptions he will be responsible for producing a revised Part L calculation and report to demonstrate compliance.

In the absence of the lighting calculation standard luminaire efficacy of 95 lm/W has been applied to the remaining zones throughout.

Spaces	Power correction factor	Lighting level (Lux)	Day light dimming	Local manual switching
Circulation	0.95	150	No	Presence
				Detection
Stairs	0.95	150	No	Presence
	0.00			Detection
Plantroom	0.95	200	No	Manual
Offices	0.95	350	No	Presence
	0.00			Detection
Lounge	0.95	300	No	Manual
Activity Room	0.95	350	No	Presence
	0.55			Detection
Staff Room	0.95	350	No	Presence
	0.55	330	110	Detection
Laundry	0.95	400	No	Manual
Cinema	0.95	350	No	Manual
Kitchen	0.95	500	No	Manual
Dining	0.05	200	No	Presence
Dining	0.95	200	NO	Detection
Stores	0.95	100	No	Presence
510165	0.95	100	NO	Detection
Meds	0.95	100	No	Presence
Ivieus	0.95	100	NO	Detection
Toilets	0.95	200	No	Presence
Tollets	0.95	200	NO	Detection
Pecentian	0.95	500	No	Presence
месерион	0.95	500	NO	Detection
Bedroom	0.95	100	No	Manual
Server	0.95	100	No	Presence
Jerver	0.95	100	NO	Detection
Bathroom	0.95	200	No	Presence
Bathroom	0.95	200	NO	Detection
Secting/Bor	0.95	250	No	Presence
Seating/ Bai	0.95	330	NO	Detection
Hair Salon	0 95	350	No	Presence
	0.95	330	NU	Detection
Comms	0.95	100	No	Manual
Library	0 95	350	No	Presence
LIDI di y	0.95	330	INU	Detection

The following table summarises the assumptions made to the electrical services installation:

6.0 Conclusion

From this report, with the design parameters used within Part L2A compliance analysis, calculation performed exceeds the requirements set out in Building Regulation Part L 2021.

From the results in Appendix I it can be noted that with the passive measures and high efficiency mechanical and electrical systems in conjunction with photovoltaic cells as renewable energy source, the Care Home at Clitheroe complies with Building Regulation Part L2A analysis.

It should be noted that the calculation and subsequent results outlined within this report have been produced from TACE stage 3 information.

Appendix I – BRUKL Report



The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Fabric element	Ua-Limit	Ua-Calc	Ui-Calc	First surface with maximum value
Walls*	0.26	0.22	0.22	External Wall 375mm
Floors	0.18	0.12	0.12	Ground Floor
Pitched roofs	0.16	0.16	0.16	Roof
Flat roofs	0.18	-	-	No flat roofs in project
Windows** and roof windows	1.6	1.38	1.56	W8A Openable
Rooflights***	2.2	-	-	No rooflights in project
Personnel doors^	1.6	1.35	1.61	D1 Louvre Door
Vehicle access & similar large doors	1.3	-	-	No vehicle access or similar large doors in pro
High usage entrance doors	3	-	-	No high usage entrance doors in project
U activit = Limiting area-weighted average U-values [W/(m ²) U active = Calculated area-weighted average U-values [W/(()] m ¹ K)]		U i Cato = Cá	alculated maximum individual element U-values [W/(m/K)]
* Automatic U-value check by the tool does not apply to c	urtain walls w	hose limitin	g standard i	s similar to that for windows.
** Display windows and similar glazing are excluded from	the U-value o	heck.	*** Values	for rooflights refer to the horizontal position.
^ For fire doors, limiting U-value is 1.8 W/m ² K				
N.B.: Neither roof ventilators (inc. smoke vents) nor swim	ning pool bas	ins are mod	felled or ch	acked against the limiting standards by the tool.

Air permeability	Limiting standard	This building
m³/(h.m²) at 50 Pa	8	5

TACE

Appendix II – EPC



TACE