

n x 600mm clear opening cover complying S EN 124 and BS 7903 See Clause E2.32	Safety, Health & Environmental Information: In addition to the hazards and risks normally associated with the types of work detailed on this drawing, please note the significant hazards identified by symbols below, INDICATES A RESIDUAL RISK AS A WARNING
Minimum clear access 600mm rete manhole sections and cover slab to be vith mortar, plastomeric or elastomeric seal o BS EN 1917 and BS 5911-3. See Clause E2.29	INDICATES A RESIDUAL RISK FOR INFORMATION and described below: Construction/Maintenance/Cleaning/Demolition Refer to Drawing:
 150mm concrete surround Chamber height (not less than 900mm) Benching slope to be 1:10 to 1:30 n precast manhole ring to be built into base concrete minimum 75mm tween top of pipe and underside of precast to be minimum 50mm to maximum 300mm 	 <u>General Notes:</u> 1. Do not scale from this drawing. 2. All dimensions are in millimetres (mm), all levels in metres (m) unless noted otherwise. 3. Discrepancies or omissions are to be reported to the Engineer prior to work commencing. 4. Materials and workmanship are to comply in all respects with current British Standard Specifications, Codes of Practice, and
225mm to underside of channel	 Building Regulations Approved Documents. 5. The copyright of this drawing is vested in the Engineer and must not be copied or reproduced without written consent. 6. The Contractor is to check and verify all building and site dimensions, levels and sewer invert levels at connection points before
4 and Clause E6.6.2 for rocker pipe details	 work commences. 7. This drawing is to be read in conjunction with all relevant specifications and drawings issued by the Engineer, Architect and other Specialists. 8.For drainage plans refer to drawing: RCF-BML-ERD-ZZ-DR-C-0550 Combined Drainage Layout

- Minimum width of benching to be 225mm

0.10

