



Key:

	Existing Building
	Proposed Concrete Slab
	Proposed Footpath
	Existing and Proposed Green Areas
	Proposed Building
	Proposed Gravel Surround
	Proposed HB2 kerbs with 125mm upstand
	Proposed BN kerbs
	Proposed EF Kerbs
	Proposed Timber Edging

Safety, Health & Environmental Information:
In addition to the hazards and risks normally associated with the types of work detailed on this drawing, please note the significant hazards identified by symbols below.

INDICATES A RESIDUAL RISK AS A WARNING

INDICATES A RESIDUAL RISK FOR INFORMATION and described below:

Construction/Maintenance/Cleaning/Demolition
Refer to Drawing:

- General Notes:**
- Do not scale from this drawing.
 - All dimensions are in millimetres (mm), all levels in metres (m) unless noted otherwise.
 - Discrepancies or omissions are to be reported to the Engineer prior to work commencing.
 - Materials and workmanship are to comply in all respects with current British Standard Specifications, Codes of Practice, and Building Regulations Approved Documents.
 - The copyright of this drawing is vested in the Engineer and must not be copied or reproduced without written consent.
 - The Contractor is to check and verify all building and site dimensions, levels and sewer invert levels at connection points before work commences.
 - This drawing is to be read in conjunction with all relevant specifications and drawings issued by the Engineer, Architect and other Specialists.

- Notes:**
- The contractor is to check all information provided prior to commencing works, and seek clarification from the engineer in respect to any ambiguities found.
 - Contractor to check insitu CBR at time of construction and adjust pavement foundation as per Table 3. Assumed Site CBR 3% <= CBR < 5%
 - Contractor to check that the existing subgrade is not frost-susceptible. If found to be frost-susceptible, contractor to ensure all material within 450mm depth from the pavement surface is non frost-susceptible by adding a capping layer below the sub-base.

Table 3: Class 2 Pavement Foundation Options

In-situ CBR	Type 1 sub base to DfT SHW Clause 803
7% - 20%	100
5% - 7%	150
3% - 5%	250
2% - 3%	325
< 2%	Consult Engineer for Advice

Rev	By / Chk'd	Date	Description
P01	DH/AM	2/07/2023	Preliminary Issue

PRELIMINARY DRAWING
This drawing is not to be used for construction



BarnsleyMarshall Limited
1 Birch Court
Blackpole East
Worcester
WR3 6SG

Tel: 01905 330550
Email: design@barnsleymarshall.co.uk
Web: www.barnsleymarshall.co.uk

Cow Shed
Elmridge Lane, Preston,
PR3 2NY

External Works

By/Chk'd	RA/GM	Date	Revision
CSH-BML-XX-XX-DR-C-0700		05/04/2023	P01
BML Job No.			Status
1000-05			-

Drawing Scale at A1: As Shown
CAD Filename: Y:\projects\100-05 Cow Shed\external-works\DWG\Cow Shed-05-04-2023-01.dwg

