

Contact: Please contact the Local Planning Authority

Date: 19 October 2023

Dear Local Planning Authority,

Thank you for inviting the Lead Local Flood Authority to comment on the below application.

Application Number:	3/2023/0754
Proposal:	Proposed change of use of agricultural land to new car park and storage yard.
Location:	Judge Walmsley Mill Longworth Road Billington BB7 9TP

PLANNING APPLICATION CONSULTATION RESPONSE

The Lead Local Flood Authority is a statutory consultee for major developments with surface water drainage, under the Town and Country Planning (Development Management Procedure) (England) Order 2015. It is in this capacity this response is compiled.

Comments provided in this representation, including conditions, are advisory and it is the decision of the Local Planning Authority whether any such recommendations are acted upon. The comments given have been composed based on the extent of the knowledge of the Lead Local Flood Authority and information provided with the application at the time of this response.

Lead Local Flood Authority Position

The Lead Local Flood Authority **objects** to the above application on the basis of:

Objection 1 – No Surface Water Sustainable Drainage Strategy

In the absence of an acceptable surface water sustainable drainage strategy to assess the principle of surface water sustainable drainage associated with the proposed development, we object to this application and recommend refusal of planning permission until further information has been submitted to the Local Planning Authority.

Reason

Lancashire County Council

PO Box 100, County Hall, Preston, PR1 0LD

Paragraphs 167 and 169 of the National Planning Policy Framework require major developments to incorporate sustainable drainage systems that:

- take account of advice from the Lead Local Flood Authority;
- have appropriate proposed minimum operational standards;
- have maintenance arrangements in place to ensure an acceptable standard of operation for the lifetime of the development; and
- where possible, provide multifunctional benefits.

The submission of basic information on how surface water is intended to be managed is vital if the Local Planning Authority is to make informed planning decisions. In the absence of acceptable information regarding surface water sustainable drainage, the Lead Local Flood Authority cannot assess whether the development proposed meets the requirements of Paragraph 169 of the National Planning Policy Framework or the Planning Practice Guidance in principle. This is sufficient reason in itself for a refusal of planning permission.

Overcoming our Objection

You can overcome our objection by submitting information that covers the deficiencies highlighted above and demonstrates how surface water will be managed on-site, to satisfy Paragraphs 167 and 169 of the National Planning Policy Framework, the Planning Practice Guidance, and the Defra Technical Standards for Sustainable Drainage Systems. If this cannot be achieved we are likely to maintain our objection to the application. Production of this information will not in itself result in the removal of an objection.

The Lead Local Flood Authority asks to be re-consulted with the results of the amended site-specific flood risk assessment and/or amended sustainable drainage strategy and/or SuDS Pro-forma. We will provide you with further comments within 21 days of receiving formal re-consultation. Re-consultations should be sent to our identified mailbox.

Our objection will be maintained until the amended documents, as outlined above, have been received. Production of the amended documents will not in itself result in the removal of an objection.

If the applicant wishes to discuss our objection with the Lead Local Flood Authority, they can do so through our <u>planning advice service</u>.

Lead Local Flood Authority - Site-Specific Advice

The following advice is provided to inform the applicant and the Local Planning Authority of any additional concerns with the application:

The Lead Local Flood Authority recognises the applicants reference that the carpark will be constructed using permeable paving, however, without evidence of a surface water sustainable drainage strategy or evidence of the permeable paving to be used in order to ensure its feasibility as well as how it will function in the event of a flood or a high ground water table. If the applicant is unable to provide the appropriate evidence of the feasibility of permeable paving at this point in the application process, the applicant should provide a 'plan b' option for appropriately draining the development area. The applicant should also include a completed copy of the Lancashire SuDS Pro-forma as required in the Validation checklist for all major applications.

Lead Local Flood Authority – General Advice

The Lead Local Flood Authority's general advice is provided through the <u>Lancashire SuDS</u> <u>Pro-forma and accompanying guidance</u>. All applications for major development are expected to follow this guidance and submit a completed SuDS pro-forma.

What this response DOES NOT cover

This response does not cover highway drainage, matters pertaining to highway adoption (s38 Highways Act 1980) and/or off-site highway works (s278 Highways Act 1980). Should the applicant intend to install any sustainable drainage systems under or within close proximity to a public road network (existing or proposed), then they would need to separately discuss the use and suitability of those systems with the relevant highway authority.

The applicant is encouraged to discuss the suitability of any overland flow routes and/or flood water exceedance with the relevant highway authority should they have the potential to impact the public highway network and/or public highway drainage infrastructure (either existing or proposed).

For the avoidance of doubt, as the Lead Local Flood Authority, we do not comment on the application of the sequential and/or exception tests.

Material Changes to this Planning Application

If there are any material changes to the submitted information which impact on surface water, the Local Planning Authority is advised to consider re-consulting the Lead Local Flood Authority via our identified mailbox.

If you decide to approve contrary to our advice

If the Local Planning Authority grants planning permission for this development contrary to our advice, then we will be unable to support this application in an appeal or to assist with the discharge of any planning conditions, including surface water or flood risk conditions that we have not recommended.

For the avoidance of doubt, as the Lead Local Flood Authority, we do not comment on the application of the sequential and/or exception tests.

The Local Planning Authority should be aware that any development built after 1 January 2012 is not eligible for Grant-in-Aid funding from central government to study or alleviate flood issues. This is set out in section 9.3 of the <u>Memorandum relating to capital grants</u> for local authorities and internal drainage boards in England.

Please send a copy of the decision notice to our identified mailbox.

Yours faithfully,

Harry McGaghey

Lead Local Flood Authority