

Ribble Valley Borough Council
Planning Section
Council Offices
Church Walk
Clitheroe
BB7 2RA

Phone: 0300 123 6780
Email: developeras@lancashire.gov.uk

Your ref: 03.2023.882
Our ref: 03.2023.882
Date: 29.11.2023

For the attention of Kathryn Hughes

Planning Application No: 3/2023/0882

Grid Ref: 376977 434552

Proposal: Replace existing gate with a door and screens within the existing opening to the front elevation, provision of festoon lighting on timber posts to front and rear seating areas and removal of existing shelter to rear.

Location: Stork Hotel Whalley Road Simonstone BB12 7NZ

Having considered the information submitted, the proposal raises no highway concerns, therefore there is no objection to this proposal.

Condition

- The limits of the illuminance shall not exceed 600 candela per square metre. Reason: To avoid glare, dazzle or distraction to passing motorists.

Kind regards

Tahira

Tahira Akhtar BA (Hons)
Technician
Highways and Transport
Lancashire County Council