

**Contact:** Please contact the Local Planning Authority

**Date:** 15 May 2024

Dear Local Planning Authority,

Thank you for inviting the Lead Local Flood Authority to comment on the below application.

**PLANNING APPLICATION CONSULTATION RESPONSE**

<b>Application Number:</b>	3/2024/0042
<b>Proposal:</b>	Approval of details reserved by conditions 6 (road adoption), 10 (surface water drainage scheme), 11 (surface water drainage operation and maintenance) , 12 (surface water drainage verification report), 13 (details of play equipment), 14 (protected species licence), 17 (electric vehicle charging points), 18 (external levels and finished floor levels), 21 (boundary treatments) and 22 (biodiversity enhancement) of planning permission 3/2023/0100.
<b>Location:</b>	Land west of Preston Road Longridge PR3 3BE

The Lead Local Flood Authority is a statutory consultee for major developments with surface water drainage, under the Town and Country Planning (Development Management Procedure) (England) Order 2015. It is in this capacity this response is compiled.

Comments provided in this representation, including conditions, are advisory and it is the decision of the Local Planning Authority whether any such recommendations are acted upon. The comments given have been composed based on the extent of the knowledge of the Lead Local Flood Authority and information provided with the application at the time of this response.

**Lead Local Flood Authority Position**

The Lead Local Flood Authority is able to **recommend the discharge of condition 10** on planning decision 3/2023/0100.

**Lancashire County Council**

PO Box 100, County Hall, Preston, PR1 0LD



The Lead Local Flood Authority is currently **unable to recommend the discharge of condition 11** on planning decision 3/2023/0100 on the basis of:

- The applicant has failed to provide evidence of a timetable for the implementation of the different management and maintenance arrangements.
- The applicant has failed to provide evidence of a pro-forma to allow the recording of each inspection and maintenance activity, as well as allowing any faults to be recorded and actions taken to rectify issues.
- The applicant has failed to provide evidence of the details for financial management including arrangements for the replacement of major components at the end of the manufacturer's recommended design life, these should be provided for the areas not being adopted by United Utilities.
- The applicant has failed to provide evidence of an agreement in principle that the proposed water and sewerage company will be adopting the piped system of the site, this is important to ensure that clear oversight and future responsibility for the drainage system has been designed for and assigned to a particular organisation or company.

The Lead Local Flood Authority is currently **unable to recommend the discharge of condition 12** on planning decision 3/2023/0100 on the basis of:

- The applicant has failed to provide evidence as outlined in the condition to provide information demonstrating a verification report of an implemented and completed surface water sustainable drainage system. For the avoidance of doubt, recommendation for the discharge of this condition cannot be provided without this evidence and prior to the surface water sustainable drainage system being constructed.

### **Lead Local Flood Authority – General Advice**

The Lead Local Flood Authority's general advice is provided through the [Lancashire SuDS Pro-forma and accompanying guidance](#). All applications for major development are expected to follow this guidance and submit a completed SuDS pro-forma.

### **What this response DOES NOT cover**

This response does not cover highway drainage, matters pertaining to highway adoption (s38 Highways Act 1980) and/or off-site highway works (s278 Highways Act 1980). Should the applicant intend to install any sustainable drainage systems under or within close proximity to a public road network (existing or proposed), then they would need to separately discuss the use and suitability of those systems with the relevant highway authority.

The applicant is encouraged to discuss the suitability of any overland flow routes and/or flood water exceedance with the relevant highway authority should they have the potential to impact the public highway network and/or public highway drainage infrastructure (either existing or proposed).

For the avoidance of doubt, as the Lead Local Flood Authority, we do not comment on the application of the sequential and/or exception tests.



**Material Changes or Additional Information to this Planning Application**

If there are any material changes to the submitted information or additional information provided after this Lead Local Flood Authority response to the Local Planning Authority which impact surface water, the Local Planning Authority is advised to re-consult the Lead Local Flood Authority. Please be aware this will be classed as a re-consultation with a full 21-day response time. Re-consultations should be sent to our identified mailbox.

Please note that should the Local Planning Authority make a decision on this application contrary to our advice, then we will be unable to support this application in an appeal or at any future discharge of conditions stage relating to conditions that the Lead Local Flood Authority have not recommended.

Please send a copy of the decision notice to our identified mailbox.

Yours faithfully,

**Harry McGaghey**

Lead Local Flood Authority

