

Ribble Valley Borough Council  
Planning Section  
Council Offices  
Church Walk  
Clitheroe  
BB7 2RA

Phone: 0300 123 6780  
Email: [developeras@lancashire.gov.uk](mailto:developeras@lancashire.gov.uk)  
Your ref: 03.2024.0216  
Our ref: 03.2024.0216  
Date: 14.05.2024

**For the attention of Emily Pickup**

**Application no.: 3.24.216**

**Proposal: Advertisement consent for vinyl wrap to the front of the proposed Medpoint prescription collection machine including white static LED strip light to top of screen.**

**Location: 40 King Street Whalley BB7 9SL**

The plans and the highway related documents submitted have been viewed and the following comments to make:

There is no objection to the proposal, however, the following conditions are recommended.

### **Conditions**

- The limits of the illuminance shall not exceed 600 candela per square metre. Reason: To avoid glare, dazzle or distraction to passing motorists.
- Any external source of lighting shall be effectively screened from the view of a driver on the adjoining public highway. Reason: To avoid glare, dazzle or distraction to passing motorists.

Kind regards

Tahira

Tahira Akhtar BA (Hons)  
Technician  
Highways and Transport  
Lancashire County Council

