

Development Control
Burnley Borough Council

Tel 0300 123 6780
Email developeras@lancashire.gov.uk

Your ref 3/2024/0234
Our ref D12/3/2024/0234
Date 17th May 2024

Dear Sirs

Application no: 2024/0234

Address: 23 Pendleton Road Wiswell BB7 9DD

**Proposal: Proposed demolition of garage and outbuilding.
Construction of two-storey extension to side and single
storey extension to rear. Creation of new window on side
elevation and creation of new parking area.**

With respect to this application, we would not wish to raise any objects to the proposals.

A plan showing the available visibility splays has been provided the annotation states that nothing will be allowed to grow or be built above 0.9m. this will ensure that the splays are kept clear of obstruction.

Should you wish to support the application we would look for the following conditions and notes to be added to your decision notice.

Conditions

a) Hardstanding surface water drainage.

The surface water from the approved driveway/hardstanding/car park should be collected within the site and drained to a suitable internal outfall. Prior to commencement of the development details of the drainage strategy shall be submitted to and approved in writing by the Local Planning Authority. The scheme shall be implemented in accordance with the approved details.

Reason: In the interest of highway safety to prevent water from discharging onto the public highway.

b) Car Parking.

Lancashire County Council
PO Box 100, County Hall, Preston, PR1 0LD



No building or use hereby permitted shall be occupied or the use commenced until the car parking area has been surfaced or paved in accordance with a scheme to be approved by the Local Planning Authority and the car parking spaces and manoeuvring areas marked out in accordance with the approved plan. The car parking area shall thereafter be kept free of obstruction and available for the parking cars at all times.

Reason: To allow for the effective use of the parking areas.

c) Construction Management Plan (CMP).

No development shall take place, including any works of demolition or site clearance, until a Construction Management Plan (CMP) or Construction Method Statement (CMS) has been submitted to, and approved in writing by the local planning authority. The approved plan / statement shall provide:

- Details of the parking of vehicles of site operatives and visitors.
- Details of loading and unloading of plant and materials.
- Measures to protect vulnerable road users (pedestrians and cyclists).
- Measures to deal with dirt, debris, mud, or loose material deposited on the highway as a result of construction.
- Measures to control the emission of dust and dirt during construction.
- Details of a scheme for recycling/disposing of waste resulting from demolition and construction works.
- Delivery, demolition, and construction working hours.

The approved Construction Management Plan or Construction Method Statement shall be adhered to throughout the construction period for the development.

Reason: - In the interests of the safe operation of the adopted highway during the demolition and construction phases.

Note: Construction Management Plan.

- There must be no reversing into or from the live highway at any time – all vehicles entering the site must do so in a forward gear and turn around in the site before exiting in a forward gear onto the operational public highway.
- There must be no storage of materials in the public highway at any time.
- There must be no standing or waiting of machinery or vehicles in the public highway at any time.
- Vehicles must only access the site using a designated vehicular access point.
- There must be no machinery operating over the highway at any time, this includes reference to loading/unloading operations – all of which must be managed within the confines of the site.
- A licence to erect hoardings adjacent to the highway (should they be proposed) may be required. If necessary, this can be obtained via the County Council (as the Highway Authority) by contacting the Council by telephoning 01772 533433 or e-mailing lhsstreetworks@lancashire.gov.uk



- All references to public highway include footway, carriageway, and verge.

Should you wish to discuss the matter further, please do not hesitate to contact me by email or by telephone on 0300 123 6780.

Yours faithfully

Simon Hardie
Highways Development Control
Lancashire County Council

