

Broad Oaks, Northcote Road, Langho, BB6 8BG

1. On a fortnightly basis:

The pool media in the filter would be backwashed to waste, the process will discharge approximately 500 Litres.

2. Emptying of the swimming pool:

If you were to empty the pool with a total volume of 41.6m³, this would be carried out at a velocity of 0.19m³ per minute

You would only empty the pool 300mm per day for structural and mechanical reasons

Any water discharged from the pool, will be carried out by our mechanical filter pump and will have no requests for drainage invert levels

The only reason that you would ever empty the pool is if someone had dropped broken glass into the pool

We would generally pump the water into either a soak-away, foul or a main drain. If there are limits in terms of capacity then we would close the valve to reduce the flow of water through at that specific time

Note for points 1 and 2

These actions are not to be undertaken during periods of heavy rain and when there are saturated ground conditions in the area