

[REDACTED]

From: Contact Centre (CRM) <contact@ribblevalley.gov.uk>
Sent: 18 November 2024 09:03
To: Planning
Subject: Planning Application Comments - 3/2024/0859 FS-Case-663060963

[REDACTED]

[REDACTED]

[REDACTED]

[REDACTED]

Planning Application Reference No.: 3/2024/0859

Address of Development: 12 Old Hive, Fish House Lane, Chipping

Comments: I have no objection to the proposed planning application. I did have concerns regarding the noise levels as the application refers to the sound power level being 68dBA. [REDACTED]
[REDACTED] that that noise level would only be likely to be reached during the coldest periods and when defrosting. Most of the time the level would be 40dBA.