

## Carly Miskell

---

**From:** Akhtar, Tahira [REDACTED]  
**Sent:** 19 March 2026 12:13  
**To:** Lucy Walker  
**Subject:** FW: 3.25.435 - 6 The Grove Whalley  
**Attachments:** 6439 - P10-A-Proposed Site Plan.pdf

### External Email

This email originated from outside Ribble Valley Borough Council. Do **NOT** click links or open attachments unless you recognize the sender and are sure the content within this email is safe.

Hi Lucy

Further to our phone call discussion, the email trial below and the proposed site plan attached. Yes this is acceptable.

- The parking areas must be constructed of a bound porous material and created before first occupation up until the lifetime of the dwelling existing in its proposed state. Reason: To ensure that satisfactory parking is provided before the dwelling hereby permitted becomes operative.

Kind regards

Tahira

Tahira Akhtar BA (Hons)  
Highway Development Control Technician  
Highway Network Management  
Highways & Transport  
Lancashire County Council  
[REDACTED]  
[REDACTED]

[www.lancashire.gov.uk](http://www.lancashire.gov.uk)

---

**From:** Lucy Walker <Lucy.Walker@ribblevalley.gov.uk>  
**Sent:** 17 March 2026 10:24  
**To:** Akhtar, Tahira <Tahira.Akhtar@lancashire.gov.uk>  
**Subject:** RE: 3.25.435 - 6 The Grove Whalley

Hi Tahira,

Following your below consultation response, the Agent has provided an amended site plan which shows a parking plan. Please could you confirm whether this is acceptable from a highway's perspective?