



The Oaks

Oak Hill

Lane Ends

Penvale

This plan is issued by Electricity North West Limited. Unless otherwise indicated Electricity North West Limited cables are laid at depths in accordance with BS4541 1 (usually 600mm for Low Voltage & 900mm for HV cables in trenches). 230V/11kV cables are laid at depths as marked. The depths and positions of Electricity North West Limited equipment was accurate as shown when the equipment was installed. However, it cannot be guaranteed that the surface level & other reference data. Therefore Electricity North West Limited accepts no responsibility for the position of Electricity North West Limited equipment being different from shown. No person, body or company, shall be released from liability for damage caused to Electricity North West Limited equipment by reason of being crossed differently to the indications on this drawing. Services are not necessarily shown but must be assumed to exist in all premises, streets and ways. There may be other Electricity North West Limited apparatus in the vicinity which is not indicated in the cable plan. Other apparatus may also be present which is owned by a third party other than Electricity North West Limited. Reference should be made to BS2 (C) 47 "Warning Danger from Underground Cables" and BS2 "Avoidance of Danger from Overhead Power Lines." Electricity North West Limited, registered number 2088540, registered office: 304 Bridgewater Place, Bridgewater Park, Warrington, WA3 5AG.

Printed by: N388102
 Date: 26/03/2006
 Easting (X): 378140
 Northing (Y): 437035
 OS Grid ref: SD 781 370



Bringing energy to your door

Based upon Ordnance Survey Digital Data with the permission of the controller of HM S.O. Crown Copyright Reserved Licence No. WAJ 100017892