

STONYHURST COLLEGE, CLITHEROE  
FIRE ESCAPE DOOR SCHEDULE -

| FLOOR REF           | DOOR REF             | A | B              | C  | D | E | F | G | H      | Comments                           |
|---------------------|----------------------|---|----------------|----|---|---|---|---|--------|------------------------------------|
| FF                  | 1 Library Door       |   |                | OK | ✓ |   |   |   | OO-F3  | Arundel Library                    |
|                     | 2 ✓                  |   |                |    | ✓ |   |   |   | OO-F1  | Square Library                     |
|                     | 3 ✓                  |   |                |    | ✓ | ✓ |   |   | OO-F2  | Very thin door to half landing     |
|                     | 4 ✓                  |   |                |    | ✓ |   |   |   |        | Store                              |
|                     | 5 ✓                  |   |                |    | ✓ |   |   |   | OO-F10 | Archivum                           |
|                     | 6 ✓                  |   |                |    | ✓ |   |   |   | OO-F10 | Stonyhurst Magazine                |
|                     | 7 ✓                  |   |                |    | ✓ |   |   |   | OO-F10 | Lobby                              |
|                     | 8 ✓                  |   |                |    | ✓ |   |   |   | OO-F10 | Office                             |
|                     | 9 ✓                  |   |                |    | ✓ |   |   |   | OO-F10 | Staircase Tower                    |
|                     | 10 ✓                 |   |                |    |   |   |   |   | OO-F11 | Staircase Tower                    |
|                     | 11 ✓                 |   |                |    |   |   |   |   | OO-F11 | Double door - Master's Common Room |
|                     | 12 No works required |   |                |    |   |   |   |   | OO-F11 | Double door - Long Room            |
|                     | 13 ✓                 |   |                |    |   |   |   |   | OO-F11 | Long Room                          |
| LIBRARY/COMMON ROOM |                      |   |                |    |   |   |   |   |        |                                    |
| GF                  | 1 OK                 |   |                |    |   |   |   |   | OF-G2  | Kitchen                            |
|                     | 2 OK                 |   |                |    |   |   |   |   | OF-G1  | Dining Room                        |
|                     | 3 OK                 |   |                |    |   |   |   |   |        | Staircase                          |
|                     | 4 OK                 |   |                |    |   |   |   |   |        | Corridor                           |
|                     | 5 ✓                  |   |                |    | ✓ |   |   |   | OF-G3  | Glass door to Chapel               |
|                     | 6 OK                 |   |                |    |   |   |   |   |        | Corridor                           |
|                     | 7 OK                 |   |                |    |   |   |   |   | OF-G4  | Sitting Room                       |
|                     | 8 OK                 |   |                |    |   |   |   |   | OF-G5  | Library                            |
|                     | 9 OK                 |   |                |    |   |   |   |   |        | Staircase                          |
|                     | 10 OK                |   |                |    |   |   |   |   |        | Lobby                              |
|                     | 11 OK                |   |                |    |   |   |   |   |        | Corridor                           |
|                     | 12 OK                |   |                |    |   |   |   |   |        | Corridor                           |
|                     | 13 ✓                 |   |                |    |   |   |   |   | OF-G6  | Bedroom                            |
|                     | 14 Not accessible    |   |                |    |   |   |   |   | OF-G8  | Flat                               |
|                     | 15 ✓                 |   | (Within frame) |    |   |   |   |   |        | Corridor                           |
|                     | 16 ✓                 |   | (Within frame) |    |   |   |   |   | OF-G10 | Kitchen                            |
|                     | 17 ✓                 |   |                |    |   |   |   |   | OF-G9  | Bedroom                            |
|                     | 18 ✓                 |   | (Within frame) |    |   |   |   |   | OF-G13 | Bedroom                            |
|                     | 19 ✓                 |   | OK             |    |   |   |   |   |        | Bedroom                            |
|                     | 20 ✓                 |   |                |    |   |   |   |   |        | Corridor                           |
|                     | 21 ✓                 |   | (Within frame) |    | ✓ |   |   |   | OF-G14 | Common Room                        |
|                     | 22 ✓                 |   | (Within frame) |    |   |   |   |   |        | Corridor                           |
|                     | 23 ✓                 |   | (Within frame) |    | ✓ |   |   |   | OF-G18 | Office                             |
|                     | 24 ✓                 |   | (Within frame) |    | ✓ |   |   |   |        | Office                             |
|                     | 25                   |   |                | OK |   |   |   |   |        | Corridor                           |

A Provide rebated intumescent and smoke seals to the existing doors with either:

D Upgrade, or replace ironmongery to suit door type and location, including w/h door closers.

i) An Envirograf Product group 76 Rebated intumescent fire and smoke seals

E Adjust existing doors to form a regular seal to all edges

with aluminium holder (sheet 1)

F Provide adequate signage on doors fit for purpose and use